

Safety Alert

Fatal Accident

We regret to inform you that on Wednesday 11 April 2012, a fatal accident occurred on one of our projects

You may be aware that a fatal accident has occurred on one of our projects as a result of a subcontractor being struck by an item of plant.

At this time our sympathies are with the family, friends and colleagues of the deceased.

We have commenced a full investigation and until the results of that investigation are known we will be taking some additional steps: I remind all personnel of our "Site Traffic and Pedestrian Management" procedures, including those relating to vehicle banksmen and I am instructing site management to stand down all projects until they have confirmed that these processes are in place and that everyone involved in these operations are fully briefed.

In addition, I am prohibiting the fuelling of plant by means of transferring fuel from one vehicle to another. All plant fuelling must be conducted at designated locations utilising proprietary fuel bowsers, with no pedestrian personnel in the vicinity whilst the vehicles are being positioned in preparation for fuelling.

This prohibition and instruction must be briefed to all personnel.



M J Easton
BBRCE Deputy Managing Director